



Pos.	Description	Material, Type	Size
1	Cover, insulated	PE	D760
2	Service opening, insulated	PE	D760
3	Tank cylinder, double wall	PE100	ID1000, SN2
4	Lifting chain	AISI316	3 mm
5	Cable inlet pipe	PE100	D50 SDR17
6	Auto-coupling	Ductile iron, epoxy coating	DN50, 2"
7	Non return valve, NBR ball	Ductile iron, epoxy coating	DN50, 2"
8	Ball valve (american nut)	AISI316	DN50, 2"
9	Pressure pipe	AISI316	DN50, 2"
10	Outlet pipe	PE100	D63 SDR17
11	Inlet pipe	PE100	D2 SDR33
12	Pump	with floating switch	H <sub>max</sub> =...m, Q <sub>max</sub> =...m <sup>3</sup> /h
13	Bottom	PE100	20 mm
14	Bolts, nuts, washers	AISI316	M8, M16
15	Alarm device Tank-Check TC-412	Optional	<input type="checkbox"/> YES / NO <input type="checkbox"/>

Outlet pipe distance from Ground Surface	H1 =	mm
Inlet pipe distance from Ground Surface	H2 =	mm
Inlet pipe diameter	D2 =	mm
Inlet pipe distance from Bottom	H3 =	mm
Inlet angle (measured clockwise from OUTLET)	α =	°
Pumba designation / code		

Drawn:	E.Ehala	<b>Pumping Station ID1000 STRONG</b> Plastic cover / 1 pump		
Approved:	J.Karolin			
www.iwsgroup.ee		Mass: kg	Product code:	Rev.
<b>Innovative Water Systems</b>		<b>NA</b>	<b>500900 / order form</b>	<b>3</b>