



## DECLARATION OF PERFORMANCE 2019/1S

1. Unique identification code of the product type:  
**STRONG PE septic 2000L (501100), 3000L (501105)**
2. Type, batch, serial number or any other element allowing identification of the construction product as required pursuant to Article 11 (4): **Serial no. 200001 – 299999 and 300001 – 399999, see product marking**
3. Intended usage of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer: **Prefabricated wastewater treatment plant for treatment of wastewater**
4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required pursuant to Article 11 (5):  
**Innovative Water Systems Ltd, Aruküla tee 65, Jüri 75301, Harjumaa, Estonia**
5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12 (2):  
**not applicable**
6. System or systems of assessment and verification of constancy of performance of the construction product as set out in Annex V: **Assessment system 3**
7. In case of the declaration of performance concerning a construction product covered by a harmonised standard: **Technical Assessment Body no 1397 (STATYBOS PRODUKCIJOS SERTIFIKAVIMO CENTRAS – SPSC) performed type test in accordance with system 3 and issued test reports: No.1397-CPR-081/A\_s, No.1397-CPR-082/A\_s, No.1397-CPR-079/A.2, No.1397-CPR-080/A.2, No.1397-CPR-090/C.6**
8. Table of declared performances:

Essential characteristics	Performance	Harmonized standard
Nominal capacity (m <sup>3</sup> )	2 / 3	EN 12566-1:2000/A1:2003
Watertightness	Passed	EN 12566-1:2000/A1:2003
Material	HDPE	EN 12566-1:2000/A1:2003
Crushing resistance (pit test)	Passed	EN 12566-1:2000/A1:2003
Hydraulic efficiency	Not applicable	EN 12566-1:2000/A1:2003

9. The performance of the product identified in points 1 & 2 is in conformity with the declared performance in point 8. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4



Marek Somelar  
Technical manager  
Innovative Water Systems Ltd



 **STRONG**

Issued on 25.02.2019